


Cotswold Transport Planning		Page 1
CTP House, Knapp Road Cheltenham Gloucestershire, GL50 3QQ	Watermill Bridge Newbury Attenuation Basin 3	
Date 15/10/2021 14:44 File Attenuation Basin 3.MDX	Designed by K.S.R. Checked by	
Innovyze	Network 2020.1.3	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FEH Rainfall Model	
Return Period (years)	21
FEH Rainfall Version	2013
Site Location GB 444817 163231 SU 44817 63231	
Data Type	Point
Maximum Rainfall (mm/hr)	75
Maximum Time of Concentration (mins)	30
Foul Sewage (l/s/ha)	0.000
Volumetric Runoff Coeff.	0.750
PIMP (%)	100
Add Flow / Climate Change (%)	0
Minimum Backdrop Height (m)	0.200
Maximum Backdrop Height (m)	1.500
Min Design Depth for Optimisation (m)	1.200
Min Vel for Auto Design only (m/s)	1.00
Min Slope for Optimisation (1:X)	500

Designed with Level Soffits



Time Area Diagram for Storm

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.534	4-8	0.236

Total Area Contributing (ha) = 0.770


Total Pipe Volume (m<sup>3</sup>) = 3.976

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section	Type	Auto Design
1.000	20.000	0.133	150.4	0.770	5.00	0.0	0.600	o	450	Pipe/Conduit		
1.001	20.000	0.120	166.7	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit		

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	E I.Area (ha)	E Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	75.00	5.20	94.433	0.770	0.0	0.0	0.0	1.66	263.3	156.4
1.001	75.00	5.33	94.300	0.000	28.5	0.0	0.0	1.01	40.2	28.5

Cotswold Transport Planning		Page 2
CTP House, Knapp Road Cheltenham Gloucestershire, GL50 3QQ	Watermill Bridge Newbury Attenuation Basin 3	
Date 15/10/2021 14:44 File Attenuation Basin 3.MDX	Designed by K.S.R. Checked by	


Innovyze Network 2020.1.3

Simulation Criteria for Storm

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1
Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FEH
Return Period (years)	21
FEH Rainfall Version	2013
Site Location	GB 444817 163231 SU 44817 63231
Data Type	Point
Summer Storms	Yes
Winter Storms	Yes
Cv (Summer)	0.750
Cv (Winter)	0.840
Storm Duration (mins)	30

Cotswold Transport Planning		Page 3
CTP House, Knapp Road Cheltenham Gloucestershire, GL50 3QQ	Watermill Bridge Newbury Attenuation Basin 3	
Date 15/10/2021 14:44 File Attenuation Basin 3.MDX	Designed by K.S.R. Checked by	

Innovyze Network 2020.1.3

Online Controls for Storm

Hydro-Brake® Optimum Manhole: 3, DS/PN: 1.001, Volume (m³): 4.7

Unit Reference MD-SHE-0113-5600-0900-5600  
 Design Head (m) 0.900  
 Design Flow (l/s) 5.6  
 Flush-Flo™ Calculated  
 Objective Minimise upstream storage  
 Application Surface  
 Sump Available Yes  
 Diameter (mm) 113  
 Invert Level (m) 94.300  
 Minimum Outlet Pipe Diameter (mm) 150  
 Suggested Manhole Diameter (mm) 1200

Control Points	Head (m)	Flow (l/s)	Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.900	5.6	Kick-Flo®	0.593	4.6
Flush-Flo™	0.269	5.6	Mean Flow over Head Range	-	4.8

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	3.9	1.200	6.4	3.000	9.8	7.000	14.7
0.200	5.5	1.400	6.9	3.500	10.6	7.500	15.2
0.300	5.6	1.600	7.3	4.000	11.3	8.000	15.7
0.400	5.5	1.800	7.7	4.500	11.9	8.500	16.2
0.500	5.2	2.000	8.1	5.000	12.6	9.000	16.6
0.600	4.6	2.200	8.5	5.500	13.1	9.500	17.0
0.800	5.3	2.400	8.9	6.000	13.7		
1.000	5.9	2.600	9.2	6.500	14.2		

CTP House, Knapp Road  
Cheltenham  
Gloucestershire, GL50 3QQ

Watermill Bridge  
Newbury  
Attenuation Basin 3



Date 15/10/2021 14:44  
File Attenuation Basin 3.MDX

Designed by K.S.R.  
Checked by


Innovyze Network 2020.1.3

Storage Structures for Storm

Tank or Pond Manhole: 3, DS/PN: 1.001

Invert Level (m) 94.300

Depth (m)	Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )
0.000	453.0	0.900	783.0

CTP House, Knapp Road Cheltenham Gloucestershire, GL50 3QQ	Watermill Bridge Newbury Attenuation Basin 3	
Date 15/10/2021 14:44 File Attenuation Basin 3.MDX	Designed by K.S.R. Checked by	

Innovyze Network 2020.1.3

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000    Additional Flow - % of Total Flow 0.000  
 Hot Start (mins) 0    MADD Factor \* 10m<sup>3</sup>/ha Storage 2.000  
 Hot Start Level (mm) 0    Inlet Coefficient 0.800  
 Manhole Headloss Coeff (Global) 0.500    Flow per Person per Day (l/per/day) 0.000  
 Foul Sewage per hectare (l/s) 0.000


Number of Input Hydrographs 0    Number of Storage Structures 1  
 Number of Online Controls 1    Number of Time/Area Diagrams 0  
 Number of Offline Controls 0    Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FEH  
 FEH Rainfall Version 2013  
 Site Location GB 444817 163231 SU 44817 63231  
 Data Type Point  
 Cv (Summer) 0.750  
 Cv (Winter) 0.840  
  
 Margin for Flood Risk Warning (mm) 300.0  
 Analysis Timestep 2.5 Second Increment (Extended)  
 DTS Status OFF  
 DVD Status OFF  
 Inertia Status OFF  
  
 Profile(s) Summer and Winter  
 Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440  
 Return Period(s) (years) 2, 30, 100  
 Climate Change (%) 0, 0, 40

								Water	
PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Level (m)
1.000	1	15 Winter	2	+0%	30/15 Summer				94.682
1.001	3	360 Winter	2	+0%	2/240 Winter				94.530

		Surcharged Flooded			Half Drain		Pipe	Level	
PN	US/MH Name	Depth (m)	Volume (m <sup>3</sup> )	Flow / Cap.	Overflow (l/s)	Time (mins)	Pipe Flow (l/s)	Status	Exceeded
1.000	1	-0.201	0.000	0.58			118.3	OK	
1.001	3	0.005	0.000	0.15			5.6	SURCHARGED	

Cotswold Transport Planning		Page 6
CTP House, Knapp Road Cheltenham Gloucestershire, GL50 3QQ	Watermill Bridge Newbury Attenuation Basin 3	
Date 15/10/2021 14:44 File Attenuation Basin 3.MDX	Designed by K.S.R. Checked by	
Innovyze	Network 2020.1.3	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000    Additional Flow - % of Total Flow 0.000  
Hot Start (mins) 0    MADD Factor \* 10m<sup>3</sup>/ha Storage 2.000  
Hot Start Level (mm) 0    Inlet Coefficient 0.800  
Manhole Headloss Coeff (Global) 0.500    Flow per Person per Day (l/per/day) 0.000  
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0    Number of Storage Structures 1  
Number of Online Controls 1    Number of Time/Area Diagrams 0  
Number of Offline Controls 0    Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model    FEH  
FEH Rainfall Version    2013  
Site Location GB 444817 163231 SU 44817 63231  
Data Type    Point  
Cv (Summer)    0.750  
Cv (Winter)    0.840

Margin for Flood Risk Warning (mm)    300.0  
Analysis Timestep 2.5 Second Increment (Extended)  
DTS Status    OFF  
DVD Status    OFF  
Inertia Status    OFF

Profile(s)    Summer and Winter  
Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440  
Return Period(s) (years)    2, 30, 100  
Climate Change (%)    0, 0, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surge	First (Y) Flood	First (Z) Overflow	Water Overflow Act.	Level (m)
1.000	1	15 Winter	30	+0%	30/15 Summer				94.974
1.001	3	360 Winter	30	+0%	2/240 Winter				94.764

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m <sup>3</sup> )	Flow / Cap. (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
1.000	1	0.091	0.000	1.33		274.1	SURCHARGED	
1.001	3	0.239	0.000	0.15		5.6	SURCHARGED	

CTP House, Knapp Road Cheltenham Gloucestershire, GL50 3QQ	Watermill Bridge Newbury Attenuation Basin 3	
Date 15/10/2021 14:44	Designed by K.S.R.	
File Attenuation Basin 3.MDX	Checked by	

Innovyze Network 2020.1.3

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FEH
FEH Rainfall Version	2013
Site Location	GB 444817 163231 SU 44817 63231
Data Type	Point
Cv (Summer)	0.750
Cv (Winter)	0.840
Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF
Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 240, 360, 480, 960, 1440
Return Period(s) (years)	2, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
1.000	1	15 Winter	100	+40%	30/15 Summer				95.474
1.001	3	480 Winter	100	+40%	2/240 Winter				95.113

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m <sup>3</sup> )	Flow / Overflow Cap. (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
1.000	1	0.591	0.000	2.35		483.1	FLOOD RISK	
1.001	3	0.588	0.000	0.15		5.6	SURCHARGED	